

ENGINEERING REPORT

ISSUE NO.: _____

MODEL:	TITLE: T565 happened LCD display E302-001 at combox	APPROVED BY:
PART NO.:	PURPOSE: Report for problem LCD display E302-001 at combox 1 checker of T565 model	CHECKED BY:
PART NAME:		ISSUED BY:
		DATE: EXT:

DETAILS: (☒ Trouble:1. Problem, 2.Cause, 3.Temporary solution, 4.Permanent solution
☐ echnical report: 1.Background, 2.Conclusion, 3.Result)

I. PROBLEM

II. INVESTIGATION

III. CONCLUSION


IV. ACTION

attached sheet for:

0

I. PROBLEM :

- Phenomenon: LCD display E302-001 at combox 1 checker
- Quantity : 5 pcs
- Model: T565
- Time happen : From Jan to Feb.23
- Line : All cell T565
- Cause : IC38 on AQUA unit NG



Detail:

No	Model	Date happened	Part no	Seri AQUA	Lot product	Q'ty
1	T565	16-Jan-23	FM3-B937	5C625A24783A	30106001	1
2	T565	17-Jan-23	FM3-B937	5C625A246C67	30104001	1
3	T565	18-Jan-23	FM3-B937	5C625A246BD5	30104001	1
4	T565	6-Feb-23	FM3-B936	5C625A247C1E	30107001	1
5	T565	7-Feb-23	FM3-B936	5C625A24A9B1	30130001	1

II. INVESTIGATION :

E302-001 happened when the light intensity is below the reference level at shading.

=> It come from ADF unit NG or AQUA unit NG.

1. Exchange AQUA unit :

	OK AQUA	NG AQUA
OK machine	OK	NG
NG machine	OK	NG (Normal machine)

=> AQUA unit NG

2. Recheck FCT :

=> Result: 5/5 pcs Pass FCT

=> FCT can't detect problem.

3. Investigate AQUA unit :

3.1 Apperance check: No detect abnormal


3.2 Measurement waveform

* AFE diagram block

Power & reference

Serial interface & analog input

Data output




attached sheet for:

0

* Measurement power signal for AFE unit

OK case

NG case



=> No detect abnormal point (power supply for AFE is OK)

* Measurement seting signal & Analog input signal for AFE unit

OK case

NG case



Zoom block 1

OK case

NG case



Block	Function/ activity	Compare OK case/ Judgement
1	Set up serial interface between AFE (IC38) & ASIC (IC1)	No detect abnormal
2	Input signal (input to AINx)	No detect abnormal
3	Output signal (after convert)	Abnormal: frequence... (see next page)

=> Suggest AFE was NG (ADC block).

attached sheet for:

0


* Measurement Analog input signal & out put signal for AFE unit

OK case

NG case



=> NG case: data output was abnormal (same with chanel AIN2,TB+/D2,TB-/D3, AIN3,TC+/D4,TC-/D5)



attached sheet for:

0



3.3 Temperature test (On IC 38)

- Normal (25~27 °C) : **Still NG**

- Cool down (10 °C) : **Still NG**

- Heat up (50 °C) : **Still NG**

=> **NG case no affect by temperature.**

3.4 Exchange IC38

	OK AQUA	NG AQUA
OK IC38	OK	OK
NG IC38	NG	NG

=> **Sure IC38 on AQUA unit was NG**

3.5 IC38 measurement by tester

=> **No detect abnormal point**

Pin no	Pin name	OK	NG
1	VSS	0	0
2	AIN1	0.49	0.5
3	AINGND1	0.49	0.5
4	AIN2	0.49	0.5
5	AINGND2	0.49	0.5
6	AIN3	0.49	0.5
7	AINGND3	0.49	0.5
8	AIN4	0.49	0.5
9	AINGND4	0.49	0.5
10	VSS	0	0
11	REF_AIN	0.49	0.5
12	ISET	0.49	0.5
13	REFP	0.39	0.43
14	REFN	0.35	0.39
15	VSS	0	0
16	VDD	0.48	0.5
17	LEDVSS	1.5	1.5
18	LEDVSS	0.6	0.6
19	LED1	0.6	0.6
20	LED2	0.6	0.6
21	LED3	0.6	0.6
22	LEDVSS	0.6	0.6
23	RCLKN	0.49	0.5
24	RCLKP	0.49	0.5

Pin no	Pin name	OK	NG
25	SEN	0.49	0.5
26	SDI	0.49	0.5
27	SCLK	0.49	0.5
28	TCLK/CK1/D7	0.49	0.5
29	TCLK/CK0/D6	0.49	0.5
30	TC/D5	0.49	0.5
31	TC/D4	0.49	0.5
32	TB/D3	0.49	0.5
33	TB/D2	0.49	0.5
34	TA/D1	0.49	0.5
35	TA/D0	0.49	0.5
36	LVDD	0.49	0.5
37	LVSS	0.5	0.6
38	DVDD_IO	0.47	0.5
39	DVSS	0	0
40	XLSYNC	0.49	0.5
41	SDO/GPIO1	0.49	0.5
42	XST/GPIO3	0.49	0.5
43	XP1	0.49	0.5
44	X1L	0.49	0.5
45	DVSS	0	0
46	VSS	0	0
47	TEST	0.49	0.5
48	AVDD_LDO	0.4	0.4

III. CONCLUSION :

- IC38 NG make printer display E302-001 .

+ Part no: WA6-3117-000

+ Maker : TI (TEXAS INSTRUMENTS)

+ Lot no:

- Why IC38 NG? --> suspect ADC block was NG .

- Rootcause :Not yet clear

IV. ACTION :

- FB Toride improve FCT --> Result: can't improve FCT

- Send part to maker support analysis.